

ČOV Klec

250EO, 56,3 m³/den

VH rozhodnutí OŽP MÚ Třeboň ze dne 6.10.2008 k vypouštění OV, platnost do 30.9.2018

VH rozhodnutí 13 690 m³/rok
1 690 m³/měsíc

4x ročně "a"

4x ročně "a"
100/130 25/50 25/50

EO	347	přítok OV	přítok (mg/l)						odtok (mg/l)					
2014	datum	m ³	CHSK-Cr	BSK5	NL	N-NH4	P	N	CHSK-Cr	BSK5	NL	N-NH4	P	N
1		500												
2	24.02.14	418	896	840	160				119	50	43			
3		489												
4		512												
5	26.05.14	672	1540	690	580	114			53	14	23	0,2		
6		583												
7		570												
8	26.08.14	739	847	390	230	95			46	6	12	1,2		
9		546												
10		419												
11	24.11.14	344	1110	910	320	154			90	22	21	53		
12		553												
	celkem	6 345	1 098,25	707,50	322,50	121,00	0,00	0,00	77,00	23,00	24,75	18,13	0,00	0,00
	t/rok		10,81	6,96	3,17	1,19	0,00	0,00	0,76	0,23	0,24	0,18	0,00	0,00
EO	371	přítok OV	přítok (mg/l)						odtok (mg/l)					
2015	datum	m ³	CHSK-Cr	BSK5	NL	N-NH4	P	N	CHSK-Cr	BSK5	NL	N-NH4	P	N
1		409												
2	16.02.15	369	1030	750	360				128	56	74			
3		429												
4		503												
5	04.05.15	540	1380	1020	570				91	38	22			
6		523												
7		480												
8		646	1170	810	360				74	35	19			
9		483												
10		457												
11	23.11.15		873	450	200				44	9	21			

12														
	celkem	4 839	1 113,25	757,50	372,50	0,00	0,00	0,00	84,25	34,50	34,00	0,00	0,00	0,00
	t/rok		10,95	7,45	3,67	0,00	0,00	0,00	0,83	0,34	0,33	0,00	0,00	0,00
EO	407	přítok OV	přítok (mg/l)					odtok (mg/l)						
2016	datum	m³	CHSK-Cr	BSK5	NL	N-NH4	P	N	CHSK-Cr	BSK5	NL	N-NH4	P	N
1		336												
2	15.02.16	388	1350	1120	450				65	19	30			
3		486												
4		480												
5	02.05.16	467	866	590	160				46	6	13			
6		670												
7		803												
8	22.08.16	712	1470	1310	750				98	17	15			
9		357												
10		531												
11		304												
12	19.12.16	429	840	300	170				30	10	4			
	celkem	5 963	1 131,50	830,00	382,50	0,00	0,00	0,00	59,75	13,00	15,50	0,00	0,00	0,00
	t/rok		11,13	8,17	3,76	0,00	0,00	0,00	0,59	0,13	0,15	0,00	0,00	0,00